

3-phase Genset What about unbalanced loads

3-phase Genset What about unbalanced loads

I've read a lot through guides and this forum, but am still not sure about unbalanced loads at the generator. Our power metering shows a base load of about 0.3-0.5kW per phase, highest imbalance we've seen so far was a difference of about 3kW between phases. Therefore my following question:

To which limit will Quattros compensate a single-phase unbalanced load? Up to their 70A max. battery charge current in worst case of an empty battery? Would that mean $2 \times 70\text{A}$, so about 6.5kW, could be transferred via DC-side to one phase of load balancing? Only for a short amount of time, of course, as the Quattros are only rated for 4kW continuous power.

Actually, it's a 24kVA generator with $\text{pf}=0.8$. But as the site is located at 3000 meters above sea level, we only get ~80% of the rated power. It therefore should be something around 15kW. If I get you right unbalanced load only is an issue if one phase exceeds 1/3 of the rated nominal power. So we're fine as long as we set the AC input current limit accordingly. In our case 20A should always be safe, right?

Contact us for free full report

Web: <https://sumthingtasty.co.za/contact-us/>

Email: energystorage2000@gmail.com



3-phase Genset What about unbalanced loads

WhatsApp: 8613816583346

